



THE CITY OF
MT. PLEASANT, MICHIGAN

CITY HALL

320 W. Broadway • 48858-2312
(989) 779-5300
(989) 773-4691 fax

PUBLIC SAFETY

804 E. High • 48858-3595
(989) 779-5100
(989) 773-4020 fax

PUBLIC WORKS

1303 N. Franklin • 48858-4682
(989) 779-5400
(989) 772-6250 fax

PRE-BID ADDENDUM NO. 1

Project Bid: 2014 Manhole Rehabilitation Project

Bid Date: February 11, 2014
Time: 1:30 p.m.

Opening: Office of the City Clerk
City Hall
320 West Broadway St.
Mt. Pleasant, MI 48858

Addendum Issued By: Division of Public Works

Date Issued: January 17, 2014

Intent: To include 2014 MANHOLE REHABILITATION PROJECT
SPECIAL CONDITIONS - attached

Bid Proposal: No change

Specifications: No change

**2014 MANHOLE REHABILITATION PROJECT
SPECIAL CONDITIONS**

SCOPE:

This project involves the rehabilitation of sanitary sewer manholes in accordance with the specifications. All work required to complete the rehabilitation, and return the manholes to full service shall be included in the unit prices in the proposal.

TIME CONSTRAINT:

The Contractor shall commence this work on May 5, 2014 and complete all work on or before June 6, 2014. Liquidated damages at the rate of \$300.00 per day will be assessed for each day the work is not completed after June 6, 2014 unless otherwise approved by the City Inspector.

SCHEDULE:

The Contractor shall notify the City Inspector regarding their schedule for performing the work at least a week prior to the work beginning. The City of Mt. Pleasant Street Department will perform basic cleaning of the structures prior to the contractor beginning work on the project.

STANDARD CONSTRUCTION SPECIFICATIONS:

The City of Mt. Pleasant Standard Construction Specifications dated February 2007 must be followed for construction on this project. They are available on the City webpage at

www.mt-pleasant.org/docs/dept/engineering/genspec07.pdf

MANHOLE LOCATIONS:

Manholes for this project are located on various local streets throughout the City. See attached location maps.

BY-PASS PUMPING:

The Contractor shall be responsible for any by-pass pumping that may be required.

