

ADDENDUM #2  
Mission Creek Off Leash Dog Park  
City of Mt. Pleasant  
August 8, 2014

The following clarifications supersede any information found in the construction plans, bidding and contract documents:

Sheet 7 of 10 (Plan Sheet)

1. The three areas of tree protection shown along the perimeter fencing in the large dog area are to be included with Alternate #4. These areas of fencing are to be constructed per the detail shown on this sheet, excluding the benches and stone dust surfacing.
2. The two benches with the stone dust shown in the thinned Poplar grove within the small dog area are also to be included with Alternate #4.

Section 32 31 13 Chainlink Fences and Gates (Technical Specification)

Part 2 – Products

2.03 Finishes

- A. Pipe: ASTM F1083; minimum of **1.8** ounces per square foot
- B. Hardware: ASTM A153; minimum of **1.8** ounces per square foot

**Each bidder must acknowledge receipt of this addendum on page 1 of the Bid Section 00300 Section 3.01.A.**

\*\*\*END OF ADDENDUM\*\*\*

Prepared by:  
ROWE Professional Services Company  
127 S. Main Street  
Mount Pleasant, MI 48858  
(989) 772-2138