



THE CITY OF MT. PLEASANT, MICHIGAN

Mt. Pleasant Parks & Recreation
320 W. Broadway • 48858-2447
(989) 779-5331 • (989) 773-6790 fax
www.mt-pleasant.org



PRE-BID ADDENDUM NO. 1

Project Bid: Island Park & Horizon Park Softball Infield Reconditioning

Bid Date: May 19, 2015

Time: 1:30 p.m.

Opening: Office of City Clerk
City Hall
320 W. Broadway St.
Mt. Pleasant, MI 48858

Addendum Issued By: Parks Department

Date Issued: May 14, 2015

Intent: 1. Clarify Pre-Bid Questions

CLARIFICATIONS:

1. Lincoln Street Bridge weight restrictions at Island Park
 - a. There is a 50 ton GROSS weight limit on the bridge per posted sign at park entrance.
2. How do you want to match the existing infield material with excavated area in the Horizon Park Field alternate?
 - a. Sod and topsoil to be excavated to a depth of 4" and filled and replaced with 2.75" of stone dust/diamond dust and top layer of 1.25" of Dura Edge Classic.

Area to be excavated	Current Infield
Dura Edge 1.25"	Dura Edge 1.25"
Match existing material level with stonedust	Existing infield material & Level