



STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
SAGINAW BAY DISTRICT OFFICE



RICK SNYDER
GOVERNOR

DAN WYANT
DIRECTOR

December 28, 2015

DEC 31 2015

Mr. Malcolm Fox
City of Mount Pleasant
1303 North Franklin
Mt. Pleasant, MI 48858

WSSN: 04530
City of Mount Pleasant

Dear Mr. Fox.:

Subject: City of Mount Pleasant, 04530
Lead and Copper Monitoring of Drinking Water Taps

We received your report for the monitoring period June 1, 2013 through September 30, 2015.

Action Levels	Results this monitoring period		Next monitoring period	
	90 th Percentile	# of Samples Above Action Level	# of Samples Required	Take Samples Within These Dates
Lead 15 parts per billion (ppb)	0.0 ppb	0	30	06/01 and 09/30/2018 Submit results to this office by October 10, 2018
Copper 1300 parts per billion (ppb)	31 ppb	0		

Ninety percent of the sites you tested are within action levels under the administrative rules promulgated under the Michigan Safe Drinking Water Act, 1976 PA 399, as amended. These results must be reported on your 2015 Consumer Confidence Report (CCR) due to our office, your customers and the local health department by July 1, 2016. Also include the following statement in the CCR, regardless of the lead and copper levels:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mt. Pleasant is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/info/lead>.


The Lead and Copper Rule requires you to provide individual lead tap results, within 30 days of learning of results, to people who receive water from sites that were sampled, even if lead was not detected. You must also send us a certification that you met all the delivery requirements along with a sample copy of your customer notice. To download the Lead and Copper Report and Consumer Notice of Lead Result Certificate in Microsoft Word or PDF format, visit <http://michigan.gov/DEQ>. Click on Water, Drinking Water, Community Water Supply, and Reporting Forms.

Samples due during the next period continue your triennial monitoring. Please make every attempt to select the same sites used in the previous monitoring period, giving Tier 1 sites first priority. If original sites are unavailable, select replacement sites based on the Tier 1, 2, and 3 criteria. We strongly encourage you to sample early in the monitoring period.

Bottles will NOT be mailed automatically. If you use the DEQ laboratory, order your bottles by calling 517-335-8184 or download the form EQP 2301 *Requisition for Water Sample Units* from <http://michigan.gov/deq>. Click on Key Topics, Laboratory Services, Drinking Water, Obtaining The Necessary Sampling Units, and test list.

If you have any questions, please contact me at 989-894-6263; kaiserr@michigan.gov; or DEQ, Office of Drinking Water and Municipal Assistance, 401 Ketchum Street, Suite B, Bay City, MI 48708.

Sincerely,



Rebecca Kaiser
Environmental Quality Analyst
Saginaw Bay District Office
Office of Drinking Water and Municipal Assistance
989-894-6263